

Date : 17 June, 2025
Our ref. : YYF 01
Your ref. : N/A

Notification to certificate No. A3 50594783 0001 and A3 50639850 0001

To whom it may concern,

We would like to notify the products of

Manufacturer: **FENECON GmbH**

Type: **FHI-20-DAH, FHI-29.9-DAH** on certificate No. **A3 50594783 0001**

Type: **FINV-6-2-DAH, FINV-10-2-DAH, FINV-15-2-DAH** on certificate No. **A3 50639850 0001**

are able to operate combined with central NS protection in case the total power of generation system over 30kVA.

In this situation, a certified central NS protection device per VDE-AR-N 4105 shall be applied at connection point of system. The information on pages E.6-E.7 of A3 50594783 0001 and A3 50639850 0001 refer to the configuration and measurement on integrated NS protection.

We appreciate your valued support and would like to offer our assistance and varied services in the approval of your products in the future.

With kind regards,

TÜV Rheinland (Shanghai) Co., Ltd.

Tobias Yang
Department Manager
Solar & Commercial Products